

Zoning Compliance/Fire Final

Building/Misc. Continued

If there is a commercial kitchen hood system, it must be operational and up to date with any service requirements, professionally serviced every 6 mos. professionally cleaned as deemed appropriate for the use of the hood system.

If there is a fire alarm the hood system will function with the alarm as required - if no fire alarm it must have a functional audio/visual device of its own

- Fire alarms, if present must have a current inspection tag, if not it will have to be site tested to insure proper function then tagged.
- Fire alarms cannot be wired to security alarms, cellular dialer required, audio/visual device required to signify water flow
- Duct detectors are to be wired for supervisory
- If fire alarm or sprinkler system is present and the facility is not open 24 hrs., a Knox box must be installed
Go to www.knoxbox.com for instructions
Call the number listed on the front if help is needed.
- If a sprinkler system is present it must have a current inspection tag, if not it will have to pass functionality tests



**** Information in this packet is subject to change and list is not all conclusive. If any questions or concerns arise please contact the Madison Fire Department.*

Madison Fire and Rescue

101 Mill Road
Madison, AL 35758

Phone: 256-772-3326
Fax: 256-772-4423
scott.adams@madisonal.gov
melvin.malone@madisonal.gov



Madison Fire and Rescue

Zoning Compliance/Fire Final Inspections



